



8, Jalan 308/146, Desa Tasik, Sg. Besi, 57000 Kuala Lumpur, West Malaysia.

Tel: 03-90593587, 90593589 Fax: 03-90593455

E-mail: inquiry@testech.com.my Website: www.testech.com.my

North Office: 48, Jalan Perusahaan Jelutong 1, 11600 Pulau Pinang, West Malaysia.

Tel: 04-2886551, 2886552 Fax: 04-2886550

E-mail: penang@testech.com.my

TEST REPORT

ISSUED BY : KUALA LUMPUR OFFICE

REPORT NO. : MIS 037/17/R 0312

DATE : 10-Apr-17

PAGE NO. : 1 OF 4

1. Test Requested : Determination of Volatile Organic Compound (VOC) Content for Paints and Varnishes.

2. Customer : DANSEA CONSTRUCTION PRODUCTS SDN. BHD.
Lot 2359, AL-78, Block C
Jalan Kampung, Kampung Baru Sungai Buloh
47000 Sungai Buloh, Selangor Darul Ehsan.

3. Project : Internal Testing

4. Date Tested : 6-Apr-17

5. Test Method : BS EN ISO 11890-2 : 2013 (Method 2)

6. Place of Testing : Permanent Laboratory

7. Remarks :
 - a) The above test is based solely on the sample submitted by customer
 - b) No copy of this report is valid without original red stamp.

The accuracy of test measurements are probability at 95% confidence level.

Copyright of this test report is owned by the issuing laboratory and may not be reproduced other than in full except with the prior written approved of the Head of the Issuing laboratory

SUMMARY OF TEST RESULTS

(VOLATILE ORGANIC COMPOUND (VOC) CONTENT FOR PAINTS AND VARNISHES)

Customer : DANSEA CONSTRUCTION PRODUCTS SDN. BHD.

Project : Internal Testing

Source : Klang Hock Plastic Sdn. Bhd.

Lab Ref : C259/17

Item	Description	Test Results
1	Green 0.12mm thick plastic sheet laminate with wire mesh (Pecaform) (g/L)	19.0
2	Green 0.12mm thick plastic sheet (g/L)	21.0

Conclusion :

Based on test result obtain and refer to Environmental Protection Agency's (EPA), USA and Department of Environment Malaysia (DOE) limit for VOC content of construction product which is 250g/L and the above test product can be consider as 'low-VOC-product' and can categories as environmental friendly product or **ECO friendly product**.

Certified by,




Yap Seow Keong
Technical Manager

Prepared by : Aida
Checked by : Suria



No. Seri :
Serial No. : **6917**



Adalah dengan ini diumumkan bahawa :

It is hereby verified that :

DANSEA CONSTRUCTION PRODUCTS SDN BHD
(909161-H)
LOT 2359, AL-78 BLOCK C
JALAN KAMPUNG
KAMPUNG BARU SUNGAI BULOH
47000 SUNGAI BULOH
SELANGOR DARUL EHSAN

Merupakan :

is :

PENGELUAR

Lokasi Kilang :

Factory Location :

LOT 2359, AL-78 BLOCK C
JALAN KAMPUNG
KAMPUNG BARU SUNGAI BULOH
47000 SUNGAI BULOH
SELANGOR DARUL EHSAN

No. Laporan :

Report No. :

FSL261017IBSC0687

Tarikh Dikeluarkan :

Issue Date :

12 JANUARI 2018

Sah Sehingga :

Valid Until :

11 JANUARI 2020

Pusat IBS, CIDB Malaysia

Galeri Kemajuan IBS
Lot 8, Jalan Chan Sow Lin
55200 Kuala Lumpur,
Malaysia

Tel: 03 92816409

Fax: 03 92815870

Laman Web
ibs.cib.gov.my

Sebagai syarikat Status IBS yang mengeluarkan produk IBS berikut:

As an IBS status company that manufactures the following IBS components:

SISTEM BERINOVATIF :
- PERMANENT FORMWORK

Kategori :

Category : **B**

DATUK IR. ELIAS ISMAIL
b.p Ketua Eksekutif
CIDB Malaysia